

# CITY OF LITCHFIELD WATER TREATMENT FACILITY 2019 WATER QUALITY REPORT

## Our Commitment to You:

Employees work around the clock, seven days a week, 365 days a year, to ensure the water delivered to you meets or surpasses EPA standards and is safe to use and consume. This report is a summary of the quality of water provided to our customers in 2019 and meets federal regulations for our facility's Consumer Confidence Report. Included in this report is information about where your water comes from, what it contains, and how it compares to standards set forth by regulatory agencies.

This year, as in years past, your drinking water met all USEPA, ILLINOIS EPA, and Illinois Dept. of Public Health drinking water health standards. Our system vigilantly safeguards its surface water supply, and we are able to report that our facility had no violation of a contaminant level or of any other water quality standard for not only 2019 but also the past 24 years..

If you have any questions about this report or concerning your water system, please contact Ray Weller, Water Superintendent at 324-2250 Monday through Friday from 7 AM until 3 PM. We want our valued customers to be informed about their water quality. If you would like to know more, you are welcome to attend any of our regularly scheduled City Council meetings held on the first and third Thursday of every month at 6:30 PM. in the Council Chambers located within the City Hall building at 120 East Ryder Street in Litchfield.

Our community uses surface water supplied by two man-made reservoirs or lakes. Our primary source is Lake Lou Yaeger and our secondary source is the Litchfield Reservoir, both located in Litchfield.

Some people may be more vulnerable to levels of contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections. People experiencing some types of these symptoms should seek advice about drinking water from health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline **(1-800-426-4791)**.

Drinking water, including bottled water, can reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Due to our success in controlling Total Trihalomethanes, a known carcinogen or cancer causing agent, our facility is on reduced monitoring for these chemicals as well as for Lead and Copper. No vulnerability waivers have ever had to be issued to our facility.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Possible contaminants consist of:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife;

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming;

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses;

\* **Organic chemical contaminant**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems;

\* **Radioactive contaminants**, which may be naturally occurring or be the result of oil and gas production and mining activities.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with *service* lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for *several* hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to *have* your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

In addition to the informational section of this Water Quality Report, we have included for your review several tables that list contaminants that were detected in your water and the contaminants that were tested for but not detected in your water.

Due to our success in controlling Total Trihalomethanes, a known carcinogen or cancer causing agent, our facility is on reduced monitoring for these chemicals as well as for Lead and Copper. No vulnerability waivers have ever had to be issued to our facility.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Possible contaminants consist of:

- Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife;
- Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming;
- Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses;

\* **Organic chemical contaminant**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems;

\* **Radioactive contaminants**, which may be naturally occurring or be the result of oil and gas production and mining activities.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with *service* lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for *several* hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to *have* your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

In addition to the informational section of this Water Quality Report, we have included for your review several tables that list contaminants that were detected in your water and the contaminants that were tested for but not detected in your water.

**Source Water Assessment**      **Lake Lou Yaeger**

Illinois EPA considers all surface water sources of public water supply to susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion.

Source Water Name	Type of Water
INTAKE (58034) LK LOU YAEGER	TOWARDS E END OF DAM SW

**Lead and Copper**

2019

**Regulated Contaminants Detected City of Litchfield**

**Definitions:**

**Action Level Goal (ALG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/27/2018	1.3	1.3	0.03	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/27/2018	0	15	1.8	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

**Definitions:**

The following tables contain scientific terms and measures, some of which may require explanation.

**Avg:**

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**Level 1 Assessment:**

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:**

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Contaminant Level or MCL:**

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:**

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum residual disinfectant level or MRDL:**

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal or MRDLG:**

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**na:**

not applicable.

**mrem:**

millirems per year (a measure of radiation absorbed by the body)

**ppb:**

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

**ppm:**

milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

**Treatment Technique or TT:**

A required process intended to reduce the level of a contaminant in drinking water

Regulated Contaminants 2019 City of Litchfield

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chloramines	2019	2	2 - 2	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2019	21	12.09 - 22.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2019	31	13.5 - 24.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2019	0.033	0.033 - 0.033	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2019	0.7	0.669 - 0.669	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Manganese	2019	3	2.5 - 2.5	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2019	4	4.1 - 4.1	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	2019	16	16 - 16			ppm	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	02/01/2016	0.361	0.361 - 0.361	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	02/01/2016	0.633	0.633 - 0.633	0	15	pCi/L	N	Erosion of natural deposits.

Turbidity	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.38 NTU	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.